

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

WESTERN MASON COUNTY WATER DISTRICT'S)
REQUEST FOR APPROVAL TO PROVIDE LESS)
STORAGE THAN THE MINIMUM REQUIRED FOR) CASE NO. 10070
ONE DAY'S SUPPLY; A DEVIATION FROM)
SUBSECTION (4) OF 807 KAR 5:066 (5))

O R D E R

By letter received October 28, 1987, Western Mason County Water District ("Western Mason") requested a deviation from Subsection (4) of 807 KAR 5:066, Section 5. Said request asked that Western Mason be relieved of the requirement to provide storage equal to one day's supply of its average daily usage.

Additional information is needed for an adequate and proper consideration of the deviation requested by Western Mason.

IT IS THEREFORE ORDERED that Western Mason shall file an original and seven copies of the following information with the Commission with a copy to all parties of record no later than January 6, 1988.

1. Provide the following information to describe the demands for water on Western Mason's water distribution system.

a. Total volumes purchased and/or produced annually for 1984, 1985 and 1986.

b. Total volumes purchased and/or produced monthly for the 12 months ending September 30, 1987.

c. Average 24-hour volume purchased and/or produced during the 12 months ending September 30, 1987.

d. Maximum 24-hour volume purchased and/or produced during the 12 months ending September 30, 1987.

e. Total days and highest number of successive days that the maximum 24-hour volume was purchased and/or produced during the 12 months ending September 30, 1987.

f. Projected maximum daily demand volumes for 1990 similar to (d) and (e) above. Describe the method by which these projections were made.

2. Provide a map of Western Mason's distribution system that shows the location and size of all distribution mains, storage tanks, pumping stations and any other significant features of the system. One inch on this map should not represent more than one mile on the ground.

3. Provide a description of each of Western Mason's storage facilities including their locations on the system and show total volume of storage on the system.

4. List the difference in volumes between total storage and (a) maximum 24-hour volume produced and/or purchased, (b) average 24-hour volume and (c) minimum 24-hour volume.

5. Provide a list of Western Mason's large volume customers by name and maximum monthly and 24-hour usage by volume and by percentage of Western Mason's maximum monthly and 24-hour volumes. Describe these customers' water storage and/or distribution facilities if any exist and any sales/purchase agreements now in effect for such customers. Explain any seasonal variations that

affect the purchase volumes of any of these customers. Describe Western Mason's curtailment plan if applicable to any of these customers. Do not list customers that are purchasing less than 5 percent of Western Mason's maximum monthly volumes.

6. Provide a technical summary of operational deficiencies of Western Mason's water system that are known from experience or that have been indicated by hydraulic analyses.

7. Show names and addresses of Western Mason's customers that are providing critical health services.

8. Show number of hours under present operating conditions that service can be continued to hospitals, schools and other similar facilities after an interruption of service by supplier when the supply requirements to be met are: (a) maximum 24-hour volume, (b) average 24-hour volume and (c) minimum 24-hour volume. Provide supplemental information as needed to explain how results for (a), (b) and (c) were obtained.

9. Describe past periods of interruption by the supplier for Western Mason. List dates and total days or hours of interruption.

10. Provide detailed information on supplier's system that delivers water to Western Mason. Include location and capacity of (a) treatment plant, (b) pumping stations, (c) storage tanks and any other facilities required for the delivery of water to Western Mason. Give the 24-hour capacity and maximum 24-hour production of plant for the 12 months ending September 30, 1987.

11. Does Western Mason's water purchase agreement place a limit on the daily or monthly volumes that its supplier will

furnish? If so, define these limits. If supplier provides certain volumes of storage for Western Mason, provide a copy of the agreement that insures the provision of this storage by supplier and a statement reflecting Western Mason's assessment of reliability of this agreement. Provide a copy of Western Mason's water purchase agreement if its particulars cannot be readily described and note the particulars of interest to the instant case. Describe any curtailment aspects of the contract.

12. Describe supplier's capability for delivery of water pressure and volume at each point of delivery to Western Mason. Describe those features of supplier's system that limit its capacity for delivery of water pressure and volume to Western Mason. Such features may include: (a) distance between supplier's tank and supplier's point of connection with Western Mason, (b) size of the connecting main between Western Mason and its supplier's tank, (c) capacity of supplier's treatment plant, (d) age of supplier's treatment plant, (e) condition of supplier's treatment plant, (f) capacity and condition of supplier's pumping stations and tanks and supplier's general ability to respond to the needs of Western Mason.

13. If the Farmers Home Administration is the holder of either all or a part of Western Mason's long-term debt, provide a copy of an FmHA letter stating its position with regard to the storage volume provided by Western Mason and the request for a deviation from PSC regulations.

14. Describe Western Mason's planning to date including its efforts to secure financing for construction of additional storage facilities.

If the above listed items of information cannot be provided by January 6, 1988, Western Mason should submit a motion for an extension of time stating the reason a delay is necessary and include a date by which it will be furnished. Such motion will be considered by the Commission. Western Mason shall furnish with each response the name of the witness who will be available for responding to questions concerning each item of information requested should a public hearing be required in this matter.

Done at Frankfort, Kentucky, this 3rd day of December, 1987.

PUBLIC SERVICE COMMISSION


For the Commission

ATTEST:

Executive Director